



INfiltrator

water technologies



**Achieving Secondary Wastewater Treatment Standards using
Zero-Energy Combined Treatment and Dispersal Technology**

David Lentz, P.E.

Content Notice

The materials being presented represent the presenter's opinions, and do NOT reflect the opinions of NOWRA.

There are multiple combined treatment and dispersal systems approved by regulatory agencies. These products are produced by several manufacturers. Since showing all designs and performance results is not practical, this presentation depicts designs from one manufacturer.

The audience can search for "combined treatment and dispersal systems" to find additional information on the topic and information on other products within the technology group.



DID YOU KNOW?

**Onsite wastewater systems
are used in 30 million
U.S. homes – serving
25% of the population**

**“...4 billion
gallons of
sewage is
treated by
onsite/
decentralized
systems in the
USA every
day.”**


USEPA



**One-third of new homes
built in the U.S.
use onsite
wastewater
treatment
systems**



Conventional Septic System



Please note: Septic systems vary. Diagram is not to scale.

<https://www.epa.gov/septic/types-septic-systems>



United States
Environmental Protection
Agency

Conventional Drainfield Distributes Wastewater



What if Wastewater Treatment is Needed?



Electromechanical systems treat wastewater to secondary standards requiring:

- Electricity
- Maintenance
- Blower
- Separate drainfield

Separate Treatment and Dispersal Systems



+



What about Treatment without Electricity?



Combined Treatment and Dispersal System



Why Combined Treatment and Dispersal?

- Two functions in one footprint
- Zero-electric passive operation
- Resilient naturally occurring microbes
- Stable, reliable performance
- High wastewater purification levels
- Design versatility for nutrient removal
- No moving parts or special maintenance
- Smaller footprint vs. legacy systems

No Special Maintenance

- Pump septic tank as needed
- If installed, clean effluent filter
- If installed, check observation ports
- Maintain vegetated system cover



CTD Provides Another Tool in the Toolbox




CTD is an Emerging Technology

- Increasing wastewater reclamation needs
- Increasing treatment system demand
- National performance standard certification availability
- Increasing energy conservation awareness
- Improved design and manufacturing methods
- Broadening regulatory recognition

CTD in 2024 Uniform Plumbing Code

- CTD included in 2024 UPC preprint
- Appendix H – Private Sewage Disposal Systems
- 2024 UPC preprint is available:
 - www.iapmo.org
 - Hover over “Codes & Standards”
 - Click on “Code Development”





**What's inside a
field-installed
combined treatment
and dispersal system?**

Integrated Technology

Manufactured CTD Product



+

System Sand




System Sand Specification


ASTM C33 – Standard Specification for Concrete Aggregates



System Sand



Typical Expanded View





What are the basic steps for CTD system construction?

Sand Bed Placement



Product Segments Connection



Product Placement on Sand Bed



System May Need to be Staked



Curved Bed Layout with Spacers



Piping Connected



System Sand Placement



Finished Above-Ground System



CTD Treatment Performance Typical Testing Results


What is Secondary Treatment?



EPA establishes secondary treatment standards for publicly owned treatment works (POTWs), which are minimum, technology-based requirements for municipal wastewater treatment plants. These standards are reflected in terms of five-day biochemical oxygen demand (BOD₅), total suspended solids (TSS) removal, and pH.

NSF/ANSI 40 Secondary Treatment Standards

| NSF/ANSI 40 Parameter | Requirement |
|----------------------------------|-------------|
| 5-day carbonaceous oxygen demand | <25 mg/l |
| Total suspended solids | <30 mg/l |
| pH | 6 to 9 |



NSF/ANSI 40 Certification and Testing



NSF/ANSI 40 Testing



- **Consistently reduces CBOD₅ and TSS concentrations:**
 - **From day 1**
 - **Throughout 26-week test**



TABLE I. SUMMARY OF ANALYTICAL RESULTS

| | <u>Average</u> | <u>Std. Dev.</u> | <u>Minimum</u> | <u>Maximum</u> | <u>Median</u> | <u>Interquartile Range</u> |
|------------------------------------|----------------|------------------|----------------|----------------|---------------|--------------------------------|
| Biochemical Oxygen Demand (mg/L) | | | | | | |
| <i>Influent (BOD₅)</i> | 180 | 52 | 100 | 430 | 160 | 140 - 200 |
| <i>Effluent (CBOD₅)</i> | 11 | 9 | 2 | 50 | 8 | 6- 14 |
| Total Suspended Solids (mg/L) | | | | | | |
| <i>Influent</i> | 210 | 71 | 45 | 650 | 190 | 170- 230 |
| <i>Effluent</i> | 7 | 3 | 2 | 18 | 6 | 5 -9 |
| pH | | | | | | |
| <i>Influent</i> | - | - | 6.0 | 7.5 | 6.9 | 6.8 – 7.2 |
| <i>Effluent</i> | - | - | 6.0 | 7.4 | 6.5 | 6.3 – 6.7 |
| Temperature (°C) | | | | | | |
| <i>Influent</i> | 17 | 5 | 8 | 23 | 19 | 13 – 21 |
| <i>Effluent</i> | 16 | 7 | 2 | 32 | 18 | 10 - 23 |
| Dissolved Oxygen (mg/L) | | | | | | |
| <i>Influent</i> | 0.4 | 0.4 | 0.1 | 2.5 | 0.2 | 0.1 – 0.5 |
| <i>Effluent</i> | 3.5 | 1.7 | 1.0 | 8.5 | 3.4 | 2.0 –4.4 |



TABLE I. SUMMARY OF ANALYTICAL RESULTS

| | <u>Average</u> | <u>Std. Dev.</u> | <u>Minimum</u> | <u>Maximum</u> | <u>Median</u> | <u>Interquartile Range</u> |
|------------------------------------|----------------|------------------|----------------|----------------|---------------|--------------------------------|
| Biochemical Oxygen Demand (mg/L) | | | | | | |
| <i>Influent (BOD₅)</i> | 180 | 52 | 100 | 430 | 160 | 140 - 200 |
| <i>Effluent (CBOD₅)</i> | 11 | 9 | 2 | 50 | 8 | 6- 14 |
| Total Suspended Solids (mg/L) | | | | | | |
| <i>Influent</i> | 210 | 71 | 45 | 650 | 190 | 170- 230 |
| <i>Effluent</i> | 7 | 3 | 2 | 18 | 6 | 5 -9 |
| pH | | | | | | |
| <i>Influent</i> | - | - | 6.0 | 7.5 | 6.9 | 6.8 – 7.2 |
| <i>Effluent</i> | - | - | 6.0 | 7.4 | 6.5 | 6.3 – 6.7 |
| Temperature (°C) | | | | | | |
| <i>Influent</i> | 17 | 5 | 8 | 23 | 19 | 13 – 21 |
| <i>Effluent</i> | 16 | 7 | 2 | 32 | 18 | 10 - 23 |
| Dissolved Oxygen (mg/L) | | | | | | |
| <i>Influent</i> | 0.4 | 0.4 | 0.1 | 2.5 | 0.2 | 0.1 – 0.5 |
| <i>Effluent</i> | 3.5 | 1.7 | 1.0 | 8.5 | 3.4 | 2.0 –4.4 |



TABLE I. SUMMARY OF ANALYTICAL RESULTS

| | <u>Average</u> | <u>Std. Dev.</u> | <u>Minimum</u> | <u>Maximum</u> | <u>Median</u> | <u>Interquartile Range</u> |
|------------------------------------|----------------|------------------|----------------|----------------|---------------|--------------------------------|
| Biochemical Oxygen Demand (mg/L) | | | | | | |
| <i>Influent (BOD₅)</i> | 180 | 52 | 100 | 430 | 160 | 140 - 200 |
| <i>Effluent (CBOD₅)</i> | 11 | 9 | 2 | 50 | 8 | 6- 14 |
| Total Suspended Solids (mg/L) | | | | | | |
| <i>Influent</i> | 210 | 71 | 45 | 650 | 190 | 170- 230 |
| <i>Effluent</i> | 7 | 3 | 2 | 18 | 6 | 5 -9 |
| pH | | | | | | |
| <i>Influent</i> | - | - | 6.0 | 7.5 | 6.9 | 6.8 – 7.2 |
| <i>Effluent</i> | - | - | 6.0 | 7.4 | 6.5 | 6.3 – 6.7 |
| Temperature (°C) | | | | | | |
| <i>Influent</i> | 17 | 5 | 8 | 23 | 19 | 13 – 21 |
| <i>Effluent</i> | 16 | 7 | 2 | 32 | 18 | 10 - 23 |
| Dissolved Oxygen (mg/L) | | | | | | |
| <i>Influent</i> | 0.4 | 0.4 | 0.1 | 2.5 | 0.2 | 0.1 – 0.5 |
| <i>Effluent</i> | 3.5 | 1.7 | 1.0 | 8.5 | 3.4 | 2.0 –4.4 |



TABLE I. SUMMARY OF ANALYTICAL RESULTS


| | <u>Average</u> | <u>Std. Dev.</u> | <u>Minimum</u> | <u>Maximum</u> | <u>Median</u> | <u>Interquartile Range</u> |
|------------------------------------|----------------|------------------|----------------|----------------|---------------|--------------------------------|
| Biochemical Oxygen Demand (mg/L) | | | | | | |
| <i>Influent (BOD₅)</i> | 180 | 52 | 100 | 430 | 160 | 140 - 200 |
| <i>Effluent (CBOD₅)</i> | 11 | 9 | 2 | 50 | 8 | 6- 14 |
| Total Suspended Solids (mg/L) | | | | | | |
| <i>Influent</i> | 210 | 71 | 45 | 650 | 190 | 170- 230 |
| <i>Effluent</i> | 7 | 3 | 2 | 18 | 6 | 5 -9 |
| pH | | | | | | |
| <i>Influent</i> | - | - | 6.0 | 7.5 | 6.9 | 6.8 – 7.2 |
| <i>Effluent</i> | - | - | 6.0 | 7.4 | 6.5 | 6.3 – 6.7 |
| Temperature (°C) | | | | | | |
| <i>Influent</i> | 17 | 5 | 8 | 23 | 19 | 13 – 21 |
| <i>Effluent</i> | 16 | 7 | 2 | 32 | 18 | 10 - 23 |
| Dissolved Oxygen (mg/L) | | | | | | |
| <i>Influent</i> | 0.4 | 0.4 | 0.1 | 2.5 | 0.2 | 0.1 – 0.5 |
| <i>Effluent</i> | 3.5 | 1.7 | 1.0 | 8.5 | 3.4 | 2.0 –4.4 |

NSF/ANSI 40 Testing




- **Fluctuating influent concentrations**
- **Consistent effluent concentrations**

CBOD₅ Treatment Performance




CBOD₅ Treatment Comparison

Product A



Product B




NSF/ANSI 40 Testing



- **No start-up period required**
- **Effectiveness is immediate**

Table II. 7- and 30-day Average Effluent CBOD₅ and 30-day Average Influent BOD₅



| Month | Week | 7-day Average Effluent CBOD ₅ (mg/L) | 30-day Average Effluent CBOD ₅ (mg/L) | 30-day Average Influent BOD ₅ (mg/L) |
|-------|------|---|--|---|
| 1 | 1 | 28 | 17 | 180 |
| | 2 | 16 | | |
| | 3 | 8 | | |
| | 4 | 11 | | |
| 2 | 5 | 15 | 14 | 170 |
| | 6 | 28 | | |
| | 7 | 16 | | |
| | 8 | 6 | | |
| | 9 | 6 | | |
| 3 | 10 | 3 | 7 | 160 |
| | 11 | 4 | | |
| | 12 | 8 | | |
| | 13 | 14 | | |
| 4 | 14 | 7 | 9 | 170 |
| | 15 | 7 | | |
| | 16 | 7 | | |
| | 17 | 12 | | |
| 5 | 18 | 14 | 8 | 160 |
| | 19 | 8 | | |
| | 20 | 8 | | |
| | 21 | 6 | | |
| | 22 | 4 | | |
| 6 | 23 | 16 | 10 | 200 |
| | 24 | 9 | | |
| | 25 | 7 | | |
| | 26 | 9 | | |

**WASTEWATER
TECHNOLOGY**

NSF/ANSI Standard 40 - Residential Wastewater Treatment Systems



NSF International
790 N. Zeeb Road
PO Box 130340
Ann Arbor, Michigan 48113-0340 USA

Table II. 7- and 30-day Average Effluent CBOD₅ and 30-day Average Influent BOD₅

| Month | Week | 7-day Average Effluent CBOD ₅ (mg/L) | 30-day Average Effluent CBOD ₅ (mg/L) | 30-day Average Influent BOD ₅ (mg/L) |
|-------|------|---|--|---|
| 1 | 1 | 28 | 17 | 180 |
| | 2 | 16 | | |
| | 3 | 8 | | |
| | 4 | 11 | | |
| 2 | 5 | 15 | 14 | 170 |
| | 6 | 28 | | |
| | 7 | 16 | | |
| | 8 | 6 | | |
| | 9 | 6 | | |
| 3 | 10 | 3 | 7 | 160 |
| | 11 | 4 | | |
| | 12 | 8 | | |
| | 13 | 14 | | |
| 4 | 14 | 7 | 9 | 170 |
| | 15 | 7 | | |
| | 16 | 7 | | |

**WASTEWATER
TECHNOLOGY**

NSF/ANSI Standard 40 - Residential Wastewater Treatment Systems



NSF International
790 N. Zeeb Road
PO Box 130540
Ann Arbor, Michigan 48113-0540 USA

Table II. 7- and 30-day Average Effluent CBOD₅ and 30-day Average Influent BOD₅

| Month | Week | 7-day Average Effluent CBOD ₅ (mg/L) | 30-day Average Effluent CBOD ₅ (mg/L) | 30-day Average Influent BOD ₅ (mg/L) |
|-------|------|---|--|---|
| 1 | 1 | 28 | 17 | 180 |
| | 2 | 16 | | |
| | 3 | 8 | | |
| | 4 | 11 | | |
| 2 | 5 | 15 | 14 | 170 |
| | 6 | 28 | | |
| | 7 | 16 | | |
| | 8 | 6 | | |
| | 9 | 6 | | |
| 3 | 10 | 3 | 7 | 160 |
| | 11 | 4 | | |
| | 12 | 8 | | |
| | 13 | 14 | | |
| 4 | 14 | 7 | 9 | 170 |
| | 15 | 7 | | |
| | 16 | 7 | | |

Missouri Field Performance Study Results

Missouri Field Performance Study


- 30 Presby Advanced Enviro-Septic systems
- Installed principally on Missouri single-family homes
- Study required per Missouri Code of State Regulations
- Objective to assess hydraulic function
- 3- to 8-year-old installations



Missouri Field Performance Study

Three geographical areas:

- Kansas City
- St. Louis
- Branson/Table Rock Lake



Missouri Field Performance Study

- Third-party investigator was Dr. Randall J. Miles, Associate Professor Emeritus, University of Missouri
- Dr. Miles lectured on soil science and agronomy for >30 years
- A Missouri Department of Health and Senior Services representative participated in the field evaluations



Missouri Field Performance Study


- Two product approvals led to differing installations:
 - **2012 approval** – 50 to 70 ft pipe/bedroom; system sand footprint based upon variable soil loading rates; 6 inches of system sand below pipe
 - **2015 approval** – 50 ft pipe/bedroom; system sand footprint 90% of area required based on soil loading rate; 6 inches of system sand below pipe
- Current product sizing is 70 ft/bedroom and 90% of area required based on soil loading rate (SLR)



Footprint Comparison


Missouri conventional gravel and pipe trench system

*5 trenches
2-ft width
90-ft long
6-ft on-center
In-ground
0.4 gpd/sf soil*



Missouri CTD system

*1 bed
3 pipe rows
70-ft long
1.5-ft on-center
In-ground
Level site
0.4 gpd/sf soil*



Missouri Field Performance Study

- Single non-intrusive, walkover visual assessment
- Assessment indicators:
 - Surfacing effluent
 - Shallow saturated soil in and around installation
 - Effluent odor and staining
- Topographical evaluation of surface flow toward installation
- Occupant interview on past system function



Missouri Field Performance Study

- DHSS requires less than 10% rate of failure
- Per DHHS approval “failure” defined as:

Failure to function properly so as to cause the discharge of untreated or partially treated wastewater onto the ground surface, or back up of effluent into the residence, due to a system design defect.



Missouri Field Performance Study

- 29 systems functioning properly
- 1 system deemed to be in a state of failure
 - Design SLR was 0.65 gpd/sf
 - Regional/area SLRs are typically 0.25 to 0.30 gpd/sf
 - System sand footprint may have been undersized
- DHSS issued general-use approval





Missouri Study - Lesson Learned


- Installation quality is critical to proper function
 - Side slopes must have correct thickness and taper
 - System sand must be adequately covered with fill
 - Surrounding topography can impact system hydraulics
 - Traffic across the system can impact effluent absorption
 - Upslope vehicle parking increases flow onto system



2019 – Evidence of Breakout



2022 – No Evidence of Breakout



2019 – Improper Installation



2019 – Improper Installation



2019 – Repair Completes Installation



2022 – No Evidence of Breakout



Lessons Learned - Surface Flow Diversion



Lessons Learned - Surface Flow Diversion




Lessons Learned - Surface Flow Diversion




CTD System Case Studies

Berkshire East Ski Resort

- 9,900 Gallons Per Day
 - Two beds handling 5,000 GPD each
- Handling facility's domestic wastewater
- Designed to account for future development growth








Blodgett Landing, Newbury, NH

50,000 GPD



5

Four Multi-Level
Pipe-Based Systems

3

Imhoff Tanks

2


Splitter

1


Head Works (Trash Filter)

4

Equalization
Tank & Pumps



Average Daily Flows 2018



| Analyte | Average | Units | Change | Analyte | Average | Units | Change |
|--------------------|---------|-------|---------------|------------------------------|-------------|------------|----------------|
| TSS - Influent | 119.1 | mg/L | -95.7% | Total Nitrogen - Influent | 28.70 | mg/L | -72.5% |
| TSS - Effluent | 5.14 | mg/L | | Total Nitrogen - Effluent | 7.89 | mg/L | |
| Nitrite - Influent | 0.50 | mg/L | -1.8% | Total Phosphorous - Influent | 4.74 | mg/L | -62.4% |
| Nitrite - Effluent | 0.49 | mg/L | | Total Phosphorous - Effluent | 1.78 | mg/L | |
| Nitrate- Influent | 1.05 | mg/L | 575% | BOD5 - Influent | 111.41 | mg/L | -94.5% |
| Nitrate - Effluent | 7.09 | mg/L | | BOD5 - Effluent | 6.13 | mg/L | |
| Ammonia - Influent | 20.56 | mg/L | -97.8% | Total Coliform - Influent | 295,489,587 | CFU/100 mL | 99.997% |
| Ammonia - Effluent | 0.46 | mg/L | | Total Coliform - Effluent | 7,931 | CFU/100 mL | |
| TKN - Influent | 27.85 | mg/L | -93.9% | Fecal Coliform - Influent | 11,917,611 | CFU/100 mL | 99.983% |
| TKN - Effluent | 1.70 | mg/L | | Fecal Coliform - Effluent | 2,072 | CFU/100 mL | |

| Analyte | Average | Units | Change | Analyte | Average | Units | Change |
|--------------------|---------|-------|---------------|------------------------------|-------------|------------|----------------|
| TSS - Influent | 119.1 | mg/L | -95.7% | Total Nitrogen - Influent | 28.70 | mg/L | -72.5% |
| TSS - Effluent | 5.14 | mg/L | | Total Nitrogen - Effluent | 7.89 | mg/L | |
| Nitrite - Influent | 0.50 | mg/L | -1.8% | Total Phosphorous - Influent | 4.74 | mg/L | -62.4% |
| Nitrite - Effluent | 0.49 | mg/L | | Total Phosphorous - Effluent | 1.78 | mg/L | |
| Nitrate- Influent | 1.05 | mg/L | 575% | BOD5 - Influent | 111.41 | mg/L | -94.5% |
| Nitrate - Effluent | 7.09 | mg/L | | BOD5 - Effluent | 6.13 | mg/L | |
| Ammonia - Influent | 20.56 | mg/L | -97.8% | Total Coliform - Influent | 295,489,587 | CFU/100 mL | 99.997% |
| Ammonia - Effluent | 0.46 | mg/L | | Total Coliform - Effluent | 7,931 | CFU/100 mL | |
| TKN - Influent | 27.85 | mg/L | -93.9% | Fecal Coliform - Influent | 11,917,611 | CFU/100 mL | 99.983% |
| TKN - Effluent | 1.70 | mg/L | | Fecal Coliform - Effluent | 2,072 | CFU/100 mL | |

Paradise, CA 100,000 GPD



Paradise, CA



2018

California 100,000 gpd FEMA Installation



- FEMA worker base camp
- Over 1,500 workers
- Kitchens and laundry facilities
- Largest CTD system to date
- 100,000 gallons per day
- Adapted for nutrient reduction



FEMA Base Camp

Paradise, CA 100,000 GPD

(4) 40k
Septic Tanks




(4) 25k
Treatment
Fields




Large & Small
Transpiration
Ponds





Near End View

SCALE: 1" = 100'



100' ACCESS EASEMENT PER BK 1518 O.R. PG 543

APN 040-520-100 MIXED USE

6" PVC SEWER MAIN PER BASE CAMP PLANS

EXIST. WELL

50' POLE LINE AND VEGETATION CLEARING EASEMENT PER BK 110 OF DEEDS PG. 140


25' POLE LINE EASEMENT TO VALLEY COUNTIES POWER COMPANY BK. 110 OF DEEDS PG 140

APN 040-520-105 AGRICULTURE (VACANT)

| ELEVATIONS AND VOLUMES FOR KEY SURFACE IMPOUNDMENT FEATURES | | | | |
|---|----------------|-------------------|---------------------|----------------------|
| DESIGN POND | | | | |
| FEATURE | ELEVATION (FT) | SURFACE AREA (AC) | STORAGE VOLUME (MG) | CREST VOLUME (AC-FT) |
| BOTTOM OF POND | 728.0 | 1.9 | 0.0 | 0.0 |
| MAXIMUM OPERATION | 749.0 | 3.7 | 15.8 | 48.6 |
| CREST | 752.0 | 4.0 | 18.5 | 59.9 |
| AUXILIARY POND | | | | |
| BOTTOM OF POND | 737.0 | 0.3 | 0.0 | 0.0 |
| MAXIMUM OPERATION | 748.0 | 0.8 | 2.0 | 8.1 |
| CREST | 752.0 | 1.0 | 2.8 | 8.9 |

CONSTRUCTION NOTES

- 1) INSTALL 2" SDR-35 PVC SLOTTED PIPE
- 2) INSTALL 4" SDR-35 PVC SEWER PIPE
- 8) INSTALL 2"-90° PVC BEND.
- 9) INSTALL 4"-45° PVC BEND.
- 24) INSTALL PRECAST CONCRETE LEACHATE COLLECTION PUMP VAULT PER DETAIL SHOWN ON SHEET 10.
- 27) INSTALL 40-MIL HDPE LINER OVER 8 OZ NON-WOVEN GEOTEXTILE FABRIC PER DETAILS SHOWN ON SHEET 10.
- 28) INSTALL LEACHATE COLLECTION SYSTEM PER DETAIL SHOWN ON SHEET 10.
- 29) CONSTRUCT 24" HDPE EQUALIZATION P.P.C.
- 30) CONSTRUCT 4" THICK MIN. GRAVEL ACCESS ROAD OVER COMPACTED BASE (WIDTH PER PLAN).
- 32) INSTALL 6" HIGH CHAIN LINK FENCE WITH 3 ROWS OF BARBED WIRE.
- 33) INSTALL 12" WIDE CHAINLINK DOUBLE SWING GATE.






SUPERIOR



System Performance Data



Thank You for Attending!

CTD Technology Summary

- Promotes wastewater reclamation
- Reduces energy demand
- Performs reliably and consistently
- Proven longevity
- Functions in all climates
- Smaller footprint vs. legacy systems





INFILTRATOR

water technologies



Presented by
David Lentz, P.E.
dlentz@infiltratorwater.com
www.infiltratorwater.com