

The materials being presented represent the speaker's own opinions and do NOT reflect the opinions of NOWRA.

Onsite wastewater research program at the Texas A&M University: Low Pressure Dosing research




Gabriele Bonaiti, Anish Jantrania, Ryan
Gerlich – Texas A&M AgriLife Extension

June Wolfe III – Texas A&M AgriLife Research


Written for presentation at the
2021 NOWRA Onsite Wastewater Mega-Conference
October 17-20, 2021 in San Marcos, Texas

Outline

- ⦿ Introduction and background
 - ⦿ Project questions
 - ⦿ Experiment methods, issues, and preliminary results
 - ⦿ Survey
 - ⦿ LPD Plumbing Configuration and experiment design
 - ⦿ Construction
 - ⦿ Wastewater distribution and monitoring
 - ⦿ Conclusions
- 




Introduction and background

- ⊙ In Texas, it is estimated that about 20% of the dwellings use On-Site Sewage Facilities (OSSF)
- ⊙ State's environmental regulatory agency awarded competitive grants supporting applied research and demonstration projects 90s-2013
- ⊙ 2017 85th Texas Legislative Session House Bill 2771
- ⊙ 2019 OSSF Grant Program (TOGP):
 - 1) Black water non-potable reuse,
 - 2) Low pressure dose systems with various configurations,
 - 3) Dosing verses non-dosing in aerobic treatment units (ATU),
 - 4) Adequacy of ATUs designs with higher strength wastewater

- ⦿ LPD advantages:
 - ⦿ Uniform distribution of effluent,
 - ⦿ Dosing and resting of soil treatment area,
 - ⦿ Shallow placement of trenches to enhance aeration
 - ⦿ LPD in Texas: 43,000 LPD permits since 1992 (about 5% of the total; up to 49% in Navarro county)
- 


Low Pressure Dose Systems

Count as of 2017




- ⦿ Texas Commission on Environmental Quality (TCEQ)

Solicitation suggests:

- ⦿ *“research is needed into whether the design can be improved”*
(effluent distribution, maintenance)
 - ⦿ Recommend revision of Texas rules (now mostly based on North Carolina State Sea Grant College Publication UNC-SG-82-03)
 - ⦿ Compare specific alternative configurations
- 


Project questions


- ⦿ What are the operational problems faced by the users and operators with the current LPD design in Texas?
 - ⦿ Can the current design with holes facing down be improved with holes facing up, to achieve better distribution of effluent and to allow for better maintenance of LPD systems?
 - ⦿ Are changes required in the current design specifications of an LPD system in 30 TAC Chapter 285, and if so, what changes are to be recommended?
- 

Experiment methods, issues, and preliminary results

- ⊙ Presentations and survey (in person, email, online): Type and magnitude of problems faced in Texas
- ⊙ Field experiment at AgriLife Waste Water Research Facility Center, at Texas A&M RELLIS Campus, Bryan Texas: Uniformity of effluent and water quality

Objectives

- 1) Conduct interviews and surveys with regulators, owners, and license holders
 - 2) Identify alternative LPD system designs and maintenance schemes
 - 3) Design the experiment
 - 4) Construct and run the experiment and monitor distribution uniformity and maintenance requirements
 - 5) Analyze the data to compare performances
 - 6) Submit final report and suggested changes to Texas regulations
- 

- ⦿ Texas OSSF Grant Program (TOGP) Committee Meetings to receive initial and final input
 - ⦿ TCEQ Quality Assurance Project Plan (QAPP)
 - ⦿ Corona-19 virus outbreak → ~~one year~~ to six months
 - ⦿ No-cost extension
- 

Survey



Survey to get your feedback for improving low-pressure dosing (LPD) design in terms of effluent distribution uniformity, and ability to maintain the system

Please complete the following questions to the best of your ability.

About you

Indicate if you are a:

- Owner Designer Installer Maintenance Provider Regulator

Estimate number of LPD systems designed/installed/maintained/inspected: _____

Observed problems

- No problems
- Orifice plugging
- Not uniform distribution
- Maintenance
- Other _____

Please describe the type and frequency of problem/s: _____

Suggestions

Indicate your suggestions for improving LPD design:

Additional comments




Observed problems*

- No problems
- Orifice plugging
- Not uniform distribution
- Maintenance
- Other

Back

Next



FAQs

How will this information be used? Texas A&M AgriLife Extension is a public entity, therefore data collected is classified as public information. Data collected from surveys may be published in a report intended for research and educational purposes.

Why should I answer these questions? TCEQ have provided Texas A&M AgriLife Extension grant money¹ to conduct research to investigate whether the design of LPD systems can be improved in terms of effluent distribution over time, and ability to maintain the distribution system².


For more information contact:

Gabriele Bonaiti
 Extension Program Specialist | Department of Biological and Agricultural Engineering
 2117 TAMU
 College Station, TX 77843-2117
 Office: 979-862-2593 Cell: 979-922-4991 Email: g.bonaiti@tamu.edu


Ryan Gerlich
 Extension Program Specialist | Department of Biological and Agricultural Engineering
 2117 TAMU
 College Station, TX 77843-2117
 Office: 979-458-4185 Cell: 713-828-1252 Email: RGerlich@tamu.edu

¹ TCEQ Solicitation 582-19-9377, RT-2.3.3


² North Carolina State Sea Grant College Publication UNC-582-03 is currently used to aid in low-pressure dosing field design

- ⦿ TCEQ approval
 - ⦿ Texas Onsite Wastewater Association annual meeting
 - ⦿ Email for online survey to all Texas Authorized Agents (AA); Qualtrics software
 - ⦿ 6,248 systems represented (system is counted for each problem indicated)
 - ⦿ Total: 45 surveys (in person + online)
 - ⦿ Online: 11% feedback, 22% not delivered, 30% contact info
 - ⦿ Results focus on orifice clogging and maintenance
- 

Observed problems, as weighted by the # of systems represented (label show # of systems)



LPD Plumbing Configuration and experiment design

- ⊙ Continuous wastewater flow from RELLIS Campus sewer
 - ⊙ Existing 3,000-gallon common tank (feed tank)
 - ⊙ Dedicated pump in the feed tank to the Septic Tank, connected to a Pump Tank by gravity
 - ⊙ Both feed tank and septic tank have overflow pipe to drain back with highwater conditions
 - ⊙ Automatic sampler installed (Sampler #21) in pump tank
- 

LPD project
plumbing
diagram
(not to scale)

RELLIS
wastewater

Lift station to
3,000 gallon
common tank

Septic Tank
for LPD
System

Pump Tank
for LPD
System

Automated
Sampler 21
Pump tank
effluent

Block 1

Block 2

C) Leaching Chamber, Holes Up


A) Control, Holes Down


A) Control, Holes Down

B) Orifice Shield, Holes Up

B) Orifice Shield, Holes Up

C) Leaching Chamber, Holes Up

- ⦿ Pump to time-dose the LPD field
 - ⦿ 2-inches supply and manifold pipes, below laterals level, check valve, pressure valve
 - ⦿ 1 ¼ inches diversion to laterals with ball valve
- 



B: Cleanout
C: Feed Tank

E: ATU 1
F: ATU 2
G: LPD Septic Tank
H: LPD Drainfield (H1-4 = Design Replicates)

I: ATU 3
J: MBR




J
I
154
29


H1
H2
H3
H4
H




D
E
F
25
28
38

G


C
B
102
61
420

- ⦿ In each trench:
 - ⦿ Sizing (30 TAC Chapter 285 and UNC-S82-03 30) in parallel to natural surface contours (50 feet long, 18 inches deep, 24 inches wide, and 5 feet apart, about 10 inches drop NE→SW)
 - ⦿ Laterals 1 inch in diameter, on top of 12 inches of washed 1/8-3/8 in-pea gravel (or hanging on top of a 2-foot large leaching chamber), 5/32-inch holes, spaced 5 feet
 - ⦿ Two inspection ports (PVC SCH40 pipes 4 inches in diameter, protected by a metal screen), laterals with turn-up and ball valve
- 

- ⦿ Three configurations with four replicates (trenches):
 - ⦿ Holes facing down (control);
 - ⦿ Holes facing up protected by orifice shields; and
 - ⦿ Holes facing up protected by leaching chambers
- 




Monitoring:

- ⦿ Effluent depth through the inspection ports once a week (additional measures after rainfall events);
 - ⦿ Laterals pressure each quarter, as column height in transparent PVC SCH40 pipes;
 - ⦿ Soil moisture along the soil profile adjacent to the trench, with TDR (Time Domain Reflectometer) sensors measured continuously;
 - ⦿ Septic tank effluent samples, once a week, analyzed for Total Suspended Solids (TSS) and 5-day Biochemical Oxygen Demand (BOD5)
- 

Block 1

Block 2



Configuration:

A) Control, Holes Down

B) Orifice Shield, Holes Up


C) Leaching Chamber, Holes Up

○ : Soil moisture monitoring station

PI: Inspection port

TI: Trench





○ : Lateral

— : TDR sensor, side view (electrodes length is 6 inches, head size is about 3x3 inches)


■ : TDR sensor, front view

■ : auger hole

■ : trench pit

Construction

- ◎ Permit to construct from Brazos County Health District
- ◎ Soil evaluation
- ◎ Drawings
- ◎ Specifications
 - ◎ Home
 - ◎ Treatment tank



OSSF Soil & Site Evaluation

Date Performed: 2/14/2020

Site Location: Onsite Wastewater Training Center – RELLIS Campus
 Proposed Excavation Depth: 18”

Soil Boring # 1				
Depth (inches)	Soil Class	Soil Texture	Groundwater/ Water Table	Topography
0 – 10”	III	Sandy Clay Loam	No	Flat
10 – 48”	IV	Silty Clay	No	Flat

Soil Boring # 2				
Depth (inches)	Soil Class	Soil Texture	Groundwater/ Water Table	Topography
0 – 12”	III	Sandy Clay Loam	No	Flat
12 – 48”	IV	Silty Clay	No	Flat

FEATURES OF SITE AREA

- Presence of 100 Year Flood Zone Yes No
- Presence of Seasonal High Water Table Yes No
- Presence of Adjacent Ponds, Streams, Water Impoundments Yes No
- Existing or Proposed Water Well in Nearby Area (within 150 feet) Yes No
- Restrictive rock horizon Yes No
- Ground Slope 0.8 %

I certify that the findings of this report are based on my field observations and are accurate to the best of my ability.

Ryan Seelich

(Signature of person performing evaluation)

2/27/2020

(Date)

OS0031317

Registration Number and Type

- ⦿ Home Specifications

- ⦿ Not a home


- ⦿ Continuous flow of 240 gpd; the one reported for a single-family dwelling (three bedrooms), less than 2,500 square feet, with Water Saving Devices

- Treatment tank Specifications

- tank size and type calculation:

Parameter	Unit	Value
Effluent Loading Rate (Ra)	gal/sf/d	0.1
Wastewater Usage Rate (V)	gpd	240
Absorptive Area (A) = V/Ra	sqft	2400

- 750-gallon concrete tank serving as septic tank
 - 750-gallon concrete tank serving as a 500-gallon septic tank and 250-gallon pump tank

- ⦿ Construction planned for the spring 2020 postponed
 - ⦿ November 3rd - December 12, 2020 (field distribution, plumbing, pump installation)
 - ⦿ December 17th head pressure tested and set to 5 feet pressure
- 







S + N





S → N

Wastewater distribution and monitoring

- ⊙ Initial monitoring of ports with only rainfall water
- ⊙ February 24, 2021, LPD pump distributing wastewater
- ⊙ Run 1 minute/hour from feed tank (~ 8.5 gall/run = 204 gal/d)
- ⊙ LPD pump tank on a demand basis (~ 3 runs/day)
- ⊙ Calibration failure \rightarrow 600 gal/d for four (4) consecutive days
- ⊙ New calibration (~ 9.2 gal/run = 221 gal/d = 92% design load)
- ⊙ One-time temporary reduction before heavy rain forecast (~ 109 gal/d, May 20, 2021).


Weather data:


- Tipping bucket rain gauge, about 100 feet from the drain field (started November 15, 2020); 0.01-inches resolution, 5-minutes interval
 - Manually from existing gauge (in some cases cumulated)
 - College Station airport weather station: precipitation, air minimum and maximum temperature, wind average and maximum speed
- 




Top image: precipitation from manual gauge, NOAA Station (KCLL), tipping bucket
 Bottom image: min and max temperature and average and max wind (KCLL)

Precipitation from
manual gauge and
tipping bucket




- Water level:
 - Started January 7, 2021
 - Initially every 1-2 days, then weekly (daily after rainfall events)
 - Water pressure:
 - Started December 17, 2020
 - Quarterly and quite uniform among laterals
 - Slightly higher 2nd and 3rd measurement, and with sediment
 - Water quality:
 - Grab samples started March 18, 2021
 - Weekly basis, BOD5 and TSS
 - BOD5 = 20-260 mg/L, TSS = 9-26 mg/L; likely, effect of filters
- 




Average water level, rainfall, wastewater daily load, bottom and top levels for the average trench (top indicating either gravel or chamber), average ground level


Water level in trenches (average of the two trenches in each block)



Individual configurations



Pressure on laterals during the experiment months (average value for each configuration and standard deviation)











Wastewater quality during the experiment months
(grab samples from LPD pump tank)

Soil monitoring:

- ⦿ Soil moisture, preliminary before construction:
 - ⦿ November 24, 2020 from 12 locations at four depths (3-9, 9-15, 15-21, 27-33 inches);
 - ⦿ Gravimetric method
 - ⦿ At 1/3 and 2/3 of the trench length, at approximate depth and location where TDR sensors were going to be located
 - ⦿ West portion of the field (Block 1) more wet (16.6% on dry weight) with respect to the East portion (14.3%); no differences among configurations


- ⦿ Soil moisture, continuous:
 - ⦿ TDR315L sensor by Acclima, Inc. (three 15cm-long rods), connected to an ACC-AGR-NODE-II-915 Acclima sensor node, which communicates wireless to a ACC-AGR-GTWY-II-915 Acclima SDI-12 sensor data gateway;
 - ⦿ The gateway communicates wireless with the Hologram website;
 - ⦿ 60 minutes measurement interval, 4 hours upload interval
 - ⦿ Installation and setup February 3-9, 2021
 - ⦿ One sensor malfunctioning replaced; one node malfunctioning and likely damaged by weather replaced; some short interruptions (weather instability, not proper connections)






○ : Lateral
 ▲ : TDR soil moisture sensor


TDR preliminary data

- ⦿ Soil physical and chemical monitoring:
 - ⦿ March 5, 2020, two locations, 7 depths (0-6, 6-9, 12-16, 18-22, 22-26, 26-30, and 30-34 inches)
 - ⦿ Texture and chemical characteristics (PSD basic, water-solution Cations/EC from saturated paste, Cation Exchange Capacity (CEC)), and clay detailed analysis (X-ray diffraction and Fourier transform infrared). No significant differences between the two locations
 - ⦿ August 11 and 20, 2021, undisturbed samples, at each TDR station and each TDR depth (24 samples).
 - ⦿ Moisture, bulk density, field capacity determined with Tempe cell, and wilting point determined with Pressure plate
- 




Soil texture observed at the South-West side (Block 1) and the North-East side (Block 2) of the LPD drain field, near the corresponding TDR sensors

Conclusions

- ⊙ Carefully planned but shorter experiment period – Focus on key work
 - ⊙ Blocks to reduce hydraulic interference and soil variability
 - ⊙ Existing features but slow set up (site, experiment, safety) and wastewater loading calibration
 - ⊙ Responses to inclement weather (multiple rain gauges, additional grading around drain field)
- 

Conclusions

- ⊙ Analysis of results not finalized
 - ⊙ Pressure uniform and not significantly different among configurations
 - ⊙ Slight differences in soil texture (effective grouping in blocks), and in water levels among configurations
 - ⊙ Effective effluent filters to reduce BOD5 and TSS
 - ⊙ Soil moisture and hydraulic properties to be analyzed
- 

Questions?



AgriLife OSSF Research Team

Gabriele Bonaiti - LPD
g.bonaiti@tamu.edu
(979) 862-2593

June Wolfe III - ATU
jwolfe@brc.tamus.edu
(254) 774-6016

Anish Jantrania - REUSE
ajantrania@brc.tamus.edu
(254) 774-6014

Ryan Gerlich – OSSF Management
rgerlich@tamu.edu
(979) 458-4185

*The materials being presented represent the speaker's own opinions and
do NOT reflect the opinions of NOWRA.*