



ENVIRONMENTAL
MANAGEMENT
SYSTEMS, INC.

Recycling and Reuse: Not a Prescriptive Formula

National Onsite Wastewater Recycling Association

MEGA Conference October 2023


Onsite Wastewater Recycling Professionals

Presenter: Robert Sweeney, MS,

OR REHS / WA Professional Onsite Wastewater Treatment System Designer


This Presentation Represents the Opinion of the Author and Does Not Reflect the Opinion of NOWRA, its Members or Sponsors of the 2023 Mega-Conference.

10505 N Portland Rd, Portland,
OR 97203, USA



LEGEND:

- | | | | |
|--|----------------------------|--|------------------------------|
| | Major Contour Line | | Storm sewer |
| | Minor Contour Line | | Former Retention Pond (1980) |
| | Railroad | | Manhole |
| | Road/Driveway | | Monitoring Well |
| | Top of Bank | | Test Pit (PNG, 1998) |
| | Property Line | | Test Pit (Kleinfelder, 2000) |
| | Buildings/Houses | | |
| | River/Slough | | |
| | Proposed Test Pit Location | | |



SCALE 1" = 120'
IF THIS BAR DOES NOT MEASURE
2" THEN DRAWING IS NOT TO
SCALE

THIS DOCUMENT IS NOT A SURVEY.
LOCATIONS OF SITE FEATURES ARE
APPROXIMATE.

SCALE: 1" = 120'
08/16/2023

EXISTING CONDITIONS
T:1N, R:1E, SEC:05, TL:1000
AERIAL SITE PLAN

DEVELOPER: [] DRAWN BY: []

**ENVIRONMENTAL
MANAGEMENT
SYSTEMS, INC**
© ALL RIGHTS RESERVED
503-353-9691
503-353-9695
www.envmgtsys.com
4080 SE International Way
Suite B112
Milwaukie, OR 97222

Test Pits 5 Oct 23

Lab Results were Not Available as of 13Oct23



12 Soil Pits were evaluated: All were found to have: disturbed structure, visible debris &/or petroleum odors.

Site Constraints

2011 Sampling w/ Exceedance Contaminants

Volatile Organic Compounds(VOCs)

Benzene

Vinyl chloride

Dichloroethane

Dichloroethene

Trichloroethene

Dichloropropane

Tetrachloroethene

Chlorobenzene

Heavy Metals

Cadmium

Copper

Zinc

Planning Restrictions

Environmental Conservation Zone Mapped w/
Green Line 75 to 200+ feet from River Bank =
Only area that is relatively un-disturbed.

Department of Environmental Quality Standards for Onsite Wastewater Treatment System Siting: Oregon Administrative Rule 340-071-0150 Site Evaluation Procedures

50 Ft setback from top of river bank with treatment standard 2:
Biochemical Oxygen Demand (BOD5) \leq 20 mg/L
Total Suspended Solids (TSS) \leq 20 mg/L
Total Nitrogen (TN) \leq 30 mg/L
Fecal Coliform Units (FC) \leq 400 Fecal Coliform / 100 mL

Red Flags for Evaluator Approval:

Disturbed Soil, Compaction, Cuts & Unknown Fills,
Soil Pits Revealed Contaminated Fill & Compressed Soil,
Best Area for Initial & Replacement Disposal Fields is Zoned as
Environmental Conservation & Deemed Unavailable by Planning.
Underground Storage Tank. (Has been removed per City BES)
Sewer Available within 5 years (Not Planned or Funded)


We Love Challenging Sites !

PROPOSED OCCUPANCY / FLOW:

- Occupants: 250 Homeless Persons x 35 g/d/c = 8,750 gpd
- Staff: 30 x 15 g/d = 450 gpd
- Washing Machines : 12 x 500 g/d each = 6,000 gpd
- TOTAL PEAK FLOW: 15,200 gpd
- AVERAGE FLOW: (1/2 Peak Flow) 7,600 gpd

OPTIONS:

- Traditional Sewer: Not Available
- Phase 1. Holding Tanks
 - Hauling Off-Site at $\geq \$0.50 \times 7,600$ gallons / day = \$3,800/day.
 - $\$3,800 \times 365.35$ days / year = \$1,387,950 / year just for pumping & hauling.
 - Monitor Actual Quantity & Quality for Future Options



Holding Tank PHASE

HOLDING TANKS WITH ALARMS. TELEMETRY & RECIRCULATION

Each Sewage Source to be Served by a 3,000 gallon Trash or Grease Interceptor Tank

Trash or Grease Interceptor Tanks Screen Solids, with Liquid Flowing to 6x 3,000 gallon Tanks To Provide Primary Treatment and Recirculate Effluent to a Pump-Out Basin Located Near Access to avoid Pumper Trucks or Sewage Hoses in the Camp Itself.

SITE CONTAMINATED SOIL STORAGE.

PROPOSED USE: PEAK 15,200 GPD HOMELESS CAMP FOR 250 RESIDENTS / 30 STAFF, 12 WASHING MACHINES. TIME-LINE: NOV 2023

COMMON RESTROOMS & LAUNDRY. FOOD PREP OFF-SITE. GARBAGE DRAIN?

Recirculation Tanks R 1&2 with 2x 10gpm pumps

Potential Future Options TBD

- Phase 2. Convert to Septic Tank Effluent Pump (STEP)
 - Pump to Sewer. Not Available
 - Requires Pumping Under the Railroad / No Easement.
 - Pump to Onsite Treatment System
 - Treatment and Disinfection Prior to:
 - Traditional Drainfield / Seepage System: Not Suitable
 - Saturated Flow By-passes Soil Treatment Capacity
- Treatment and Bio Remediation Via Subsurface Dripfield,
 - Augmented in Modified Soils, incorporating Symbiotic Effects of:
 - Phyto-Remediation with Native Trees and Shrubs, &
 - Myco-Remediation via Mushroom Compost (various species)
 - Bio-Remediation via Soil Microbial & Effluent Bacterial & Action
 - Requires Application & Design in Accordance with Oregon *Administrative Rule (OAR 340-052-0050) for Sewage Systems Utilizing New or Unproven Technology.*
 - *This May be considered after Holding Tanks Are in Place.*

Oregon Administrative Rules in Support of Innovation in Wastewater Treatment & Reuse.

340-055-0007

Policy

It is the policy of the Environmental Quality Commission to encourage the use of recycled water for domestic, agricultural, industrial, recreational, and other beneficial purposes in a manner which protects public health and the environment of the state. The use of recycled water for beneficial purposes will improve water quality by reducing discharge of treated effluent to surface waters, reduce the demand on drinking water sources for uses not requiring potable water, and may conserve stream flows by reducing withdrawal for out-of-stream use.

REVIEW OF PLANS AND SPECIFICATIONS

340-052-0050


Treatment Works and Sewerage Systems Utilizing New or Unproven Technology

The Department encourages the development of new technology and will approve plans of such provided adequate documentation is submitted. The burden of proof for demonstrating new processes, treatment systems, and technologies lies with the design engineer. Documented case histories where any such new application has been successfully and similarly demonstrated or operated on a full scale basis shall be submitted. Demonstrations shall be at other than bench scale and shall be at field conditions such that the prototype information can be validly scaled up to a working facility. Experimental data need not be acquired solely from actual permanent operating facilities. For all such proposals, contingency plans shall be presented which will assure that in event of failure, public health and water quality would be protected.

Statutory/Other Authority: ORS 468

10505 N Portland Rd, Portland,
OR 97203, USA

Preliminary Holding Tank Conceptual Design for Coordination ONLY



FACILITY LEGEND:

H-1	5 TOILET/SHOWER RMS, 3W/D or 2 w/s + 2wh
H-2	4 TOILET/SHOWER RMS, 6 W/D
H-3	4 TOILET/SHOWER RMS, 1 W/D (ASA RR & W/D)
O-1	KITCHEN/FIRST AID & W/D & WH
O-2	4 PRIVATE OFFICES
O-3	OPEN OFFICES
O-4	OFFICES & CHECK-IN

NEW

0 10 20 40

SCALE 1" = 20'

IF THIS BAR DOES NOT MEASURE
2" THEN DRAWING IS NOT TO
SCALE

THIS DOCUMENT IS NOT A SURVEY.
LOCATIONS OF SITE FEATURES ARE
APPROXIMATE.

SCALE: 1" = 20'

08/16/2023

T: 1N, R: 1E, SEC: 05, TL: 1000

TANK PLAN

RECORD BY: ENVIRONMENTAL MANAGEMENT SYSTEMS, INC


DATE: 08/16/2023

© ALL RIGHTS RESERVED

TEL: 503-353-9691
FAX: 503-353-9695
WWW.ENVMGTSYS.COM

4080 SE International Way
Suite B112
Milwaukie, OR 97222

POST - TRASH TANK
PROCESSING FOR
AERATION,
RECIRCULATION &
EASY ACCESS TO
PUMP-OUT
OPERATIONS.



Minimum Tankage for Holding or Septic Tanks is $2 \times \text{Peak Flow} = 15,200 \text{ gpd} \times 2 = 30,400 \text{ gallons}$. Larger Fiberglass Reinforced Plastic (FRP) tanks were considered, but cannot be provided in time to meet City Schedule.

08/16/2023

T-1N, R-1E, SEC-05, TL-1000


INTERTIERED TANK ISOMETRIC VIEW

Holding Tank (H1)

Letter	Component	Elevation from Tank Floor (Inches)	Elevation from Tank Top (Inches)	Estimated Elevation from TBM (feet)
A	Ground Surface	116.00	32.00	0.00
B	Top of Tank	84.00	0.00	-2.67
C	Ceiling of Tank	80.00	-4.00	-3.00
D	Inlet Invert	74.00	-10.00	-3.50
E	RSV Manifold	na	na	na
F	RSV Stinger Seat	na	na	na
G	Outlet Invert	72.00	-12.00	-3.67
H	Outlet Opening	na	na	na
I	Alarm (HWA)	68.00	-16.00	-4.00
J	Pump On	na	na	na
K	Pump Off	na	na	na
L	na	na	na	na
M	Redundant Off	na	na	na
N	Vault Inlet Holes	na	na	na
O	Pump Intake	na	na	na
P	Floor of Tank	0.00	-84.00	-9.67
Q	Bottom of Tank	-4.00	-88.00	-10.00
R	Excavation	-8.00	-92.00	-10.33


Holding Tank (H2)

Letter	Component	Elevation from Tank Floor (Inches)	Elevation from Tank Top (Inches)	Estimated Elevation from TBM (feet)
A	Ground Surface	120.00	36.00	0.00
B	Top of Tank	84.00	0.00	-3.00
C	Ceiling of Tank	80.00	-4.00	-3.33
D	Inlet Invert	74.00	-10.00	-3.83
E	RSV Manifold	na	na	na
F	RSV Stinger Seat	na	na	na
G	Outlet Invert	na	na	na
H	Outlet Opening	na	na	na
I	Alarm (HWA)	41.72	-42.28	-6.52
J	Pump On	na	na	na
K	Pump Off	na	na	na
L	na	na	na	na
M	Redundant Off	na	na	na
N	Vault Inlet Holes	na	na	na
O	Pump Intake	na	na	na
P	Floor of Tank	0.00	-84.00	-10.00
Q	Bottom of Tank	-4.00	-88.00	-10.33
R	Excavation	-8.00	-92.00	-10.67



**TYPICAL DRAWING
- NOT FOR
CONSTRUCTION**

NOTE: CHECK
WITHTIGHTNESS OF
FERNCO COUPLERS



4" ϕ COUPLER
FOR UPPER
PIPE


08/16/2023

T: 1/N, R: 1/E, SEC: 05, TL: 1000

TANK DETAILS (H1 & H2)

Types of Water Reuse

- Sources of water include municipal wastewater, industry process and cooling water, stormwater, agriculture runoff and return flows, and produced water from natural resource extraction activities.
- These sources of water are adequately treated to meet “fit-for-purpose specifications” for a particular next use.
 - For example, reclaimed water for crop irrigation would need to be of sufficient quality to prevent harm to plants and soils, maintain food safety, and protect the health of farm workers.
 - In uses where there is a greater human exposure water may require more treatment.



SITE CONTAMINATED SOIL STORAGE.

PROPOSED USE: PEAK 15,200 GPD HOMELESS CAMP FOR 250 RESIDENTS / 30 STAFF, 12 WASHING MACHINES. TIME-LINE: NOV 2023

COMMON RESTROOMS & LAUNDRY. FOOD PREP OFF-SITE. GARBAGE DRAIN?

PHASE 1
HOLDING TANKS WITH ALARMS. TELEMETRY & RECIRCULATION

PHASE 2:
TREATMENT & DISPERSAL FOR SITE & SOIL REMEDIATION

SOILS TO BE MODIFIED WITH MUSHROOM COMPOST FOR PHYTO & MYCO REMEDIATION.

FUTURE TREATMENT IF NEEDED BASED ON MEASURED QUANTITY & QUALITY.

Covered Dumpster with Drain to OSTs?

3,000 GALLON CONCRETE TANKS

AERATOR TANKS 1&2

H 1&2 Tanks to be Pumped Daily Until Phase 2.

Recirculation Tanks R 1&2 with 2x 10gpm pumps

HEADWORKS

FLUSH RETURN LINE

DRIPFIELD

DRIPFIELD

DRIPFIELD


DRIPFIELD

DRIPFIELD

DRIPFIELD

10505 N Portland Rd, Portland,
OR 97203, USA

??
Recirculate
Plume
Water to
Soils with
Myco-Phyto
Remediation
Dripfield ??.



LEGEND:

- | | | | |
|--|------------------------------|--|---------------------------------|
| | Major Contour Line | | Manhole |
| | Minor Contour Line | | Monitoring Well |
| | Railroad | | Test Pit (PNG, 1998) |
| | Road/Driveway | | Test Pit (Kleinfelder, 2000) |
| | Property Line | | Reserve Dripfield |
| | Buildings/Houses | | Initial Dripfield |
| | River/Slough | | Areas with 50% slope or greater |
| | Storm sewer | | |
| | Former Retention Pond (1980) | | |

FACILITY LEGEND:

- H-1 5 TOILET/SHOWER RMS, 3W/D or 2 w/s + 2wh
- H-2 4 TOILET/SHOWER RMS, 6 W/D
- H-3 4 TOILET/SHOWER RMS, 1 W/D (ASA RR & W/D)
- O-1 KITCHEN/FIRST AID & W/D & WH
- O-2 4 PRIVATE OFFICES
- O-3 OPEN OFFICES
- O-4 OFFICES & CHECK-IN

0 60 120 240

SCALE 1" = 120'

IF THIS BAR DOES NOT MEASURE
2" THEN DRAWING IS NOT TO
SCALE

THIS DOCUMENT IS NOT A SURVEY.
LOCATIONS OF SITE FEATURES ARE
APPROXIMATE.

SCALE: 1" = 120'

08/16/2023

T: 1N, R: 1E, SEC: 05, TL: 1000

AERIAL SITE PLAN

CREATED BY: [Blank]

DRAWN BY: [Blank]

EMS

ENVIRONMENTAL MANAGEMENT SYSTEMS, INC

© ALL RIGHTS RESERVED

☎ 503-353-9691
☎ 503-353-9695
www.envmgtsys.com

4080 SE International Way
Suite B112
Milwaukie, OR 97222


AREA NUMBER & SqFt of Area		PEAK FLOW @ 15,200 gpd = gpd/SqFt	AVERAGE FLOW @ 7,600 gpd = gpd/SqFt
1.	67,423	0.23 gpd/SqFt	0.11 gpd/SqFt
2.	59,926	0.25 gpd/SqFt	0.13 gpd/SqFt
3.	115,696	0.13 gpd/SqFt	0.07 gpd/SqFt
TOTAL.	243,045	0.06 gpd/SqFt	0.03 gpd/SqFt

1 Inch of Rainfall = 0.623 gpd / SqFt (at the high range for Rainfall for this location)

Lawn Irrigation Typically Calls for 1 inch of water per week in the summer months.


DEQ Staff expressed Concerns about the Option of Considering Soil Remediation because of the potential for contamination to be carried deeper into the water table and river.

Dripfield Emitter Pattern




Battelle-Northwest's biobarrier technology excludes plant roots from drip emitters for upto 20 years.

Soil Wetting Pattern at Emitters



Topographic considerations




What are Bio-, Phyto- and Myco-Remediation?

Working with plants to clean up contaminated soil or water is called 'phytoremediation' and working with fungi to clean soil or water is called 'mycoremediation.' There are decomposer fungi who break down organic materials for food and can also break down some contaminants, and mycorrhizal fungi (aka "plant friend" fungi) which connect to plants through the roots and help plants grow, who can enhance or inhibit hazardous metal uptake into plants. Phyto and myco – remediation are part of a larger approach known as biological remediation or bioremediation for short.


- processes involving working with living plants to remove or contain heavy metals or degrade certain organic contaminants in-situ (on-site)

Phytoremediation




- processes involving working with bacteria to decompose organic contaminants in-situ or ex-situ (off-site)

Bio or Microbial Remediation



- processes engaging the decomposing superpowers of fungi to degrade organic contaminants or contain metals

Mycoremediation



Testing Locally-Adapted and Sustainable Solutions for Brownfields Cleanup



Taylor Yard, one of the study pilot locations, a former railyard on the LA river.

Researchers at the University of California, Riverside have teamed up with the City of Los Angeles and several community land trusts to test a soil clean up method involving native plants and fungi in a 1-year research field study launching this winter. UCR researchers in the Environmental Sciences and Toxicology department found that some plants and fungi growing naturally on contaminated sites around Los Angeles take up metals such as lead and cadmium from the soil

The field study will test these biological remediation combinations:

University of California, Riverside Study

- Native plants (pictured below)
- Native soil fungi
- Commercial Mycorrhizal Fungal Inoculum
- Decomposer Fungal Inoculum
 - with and without irrigation



(Telegraphweed)



California Buckwheat



Bob Sweeney, MS, REHS
President, EMS,

- bob@envmgtsys.com O: 503-353-9691

Will cover the following slides,
if Time Allows:

Supporting Information
REGARDING
Bio-Phyto-Myco-Remediation of
Contaminated Soils

Oregon TREATMENT & DISINFECTION IN ONSITE WASTEWATER TREATMENT DISPOSAL SYSTEMS

Biological Treatment Typically Achieves Better than Treatment **Standards** for Non-Reuse / Disposal Systems of the following:

Oregon TS2

BOD5 <20mg/L

TSS <20mg/L

TN <30mg/L

Typical Results

<10mg/L

<10mg/L

<10mg/L

Disinfection to 99% effectiveness via

Ultra Violet Rays

Ozone

Onsite Systems Rarely: use ANY Chlorine or Iodine

EPA Class D Recycled Water:

- **Description:** Class D recycled water receives basic treatment to reduce suspended solids and some contaminants. It's typically used for non-potable applications where there's minimal potential for human exposure.
- **Beneficial Uses:**
 - Landscape Irrigation: Typically for less sensitive areas.
 - Industrial Uses: Non-potable industrial processes, dust control, and construction.

OREGON. The following requirements apply to **Class D recycled water**. Any beneficial purpose authorized in writing by the department.

Treatment.

Must not exceed a 30-day log mean of 126 E. coli organisms per 100 mL & 406 E. coli CFU per 100 mL in any single sample.

Monitoring for E. coli organisms must occur once per week at a minimum.

EPA Class C Recycled Water:

•**Description:** Class C recycled water receives basic treatment to reduce suspended solids and some contaminants. It's typically used for non-potable applications where there's minimal potential for human exposure.

•**Beneficial Uses:**

- Landscape Irrigation: Typically for less sensitive areas.
- Industrial Uses: Non-potable industrial processes, dust control, and construction.

OREGON. The following requirements apply to Class C recycled water.
Any beneficial purpose authorized in writing by the department.

Treatment. Must be Oxidized and Disinfected

Must not exceed a 30-day log mean of 23 Total Coliform organisms per 100 mL & 240 TC per 100 mL in any two consecutive samples.

Monitoring for E. coli organisms must occur once per week at a minimum.

EPA Class B Recycled Water:

•**Description:** Class B recycled water undergoes treatment to reduce pathogens and contaminants, though not to the same extent as Class A water. It's suitable for uses that don't involve direct human contact or consumption.

•**Beneficial Uses:**

- Landscape Irrigation: Similar to Class A, but not in areas with public access.
- Agricultural Irrigation: Irrigating crops and non-food plants.
- Industrial Uses: Non-potable industrial processes and cooling.

OREGON. The following requirements apply to Class B recycled water.

Any beneficial purpose authorized in writing by the department.

Treatment.

Must not exceed a 30-day log mean of 2.2 E. Total Coliform organisms per 100 mL & 23 CFU per 100 mL in any single sample.

Monitoring for Total Coliform organisms must occur Three Times per week at a minimum.

EPA Class A Recycled Water:

Description: Class A recycled water undergoes advanced treatment processes that effectively remove pathogens, suspended solids, organic matter, and other contaminants.

Beneficial Uses: Landscape Irrigation: Watering lawns, gardens, parks, and other green spaces. Agricultural Irrigation: Irrigating crops and farmlands. Industrial Uses: Cooling water, process water, and non-potable industrial purposes. Toilet Flushing: Using recycled water for flushing toilets in commercial and residential buildings.

OREGON. The following requirements apply to Class A recycled water.

Treatment. oxidized, filtered and disinfected

Turbidity must not exceed avg of 2 nephelometric turbidity units (NTU) within a 24-hour period, 5 NTU more than five percent of the time within a 24-hour period, and 10 NTU at any time,

Must not exceed a 30-day log mean of 2.2 Total Coliform organisms per 100 mL & 23 CFU per 100 mL in any single sample.

Monitoring for Total Coliform organisms must occur Once per Day at a minimum.
Turbidity must be sampled at least hourly.

EPA Unrestricted Recycled Water:

- **Description:** This is the highest quality recycled water that meets stringent treatment requirements. It's treated to a level where it can be safely used for essentially any non-potable application, including those with human exposure.

- **Beneficial Uses:**

- All the above uses, including more sensitive applications like spray irrigation in urban areas, decorative fountains, and even indoor uses like flushing toilets and urinals.

OREGON. Not Found in Oregon Rules

Several technologies are commonly used in wastewater treatment and reuse to achieve effective treatment and ensure water quality for various reuse applications. Here are some of the technologies frequently employed:

It's important to note that the selection of technologies depends on the specific characteristics of the wastewater, desired water quality, regulatory requirements, and the intended reuse application. Often, a combination of several treatment processes is employed to achieve the desired treatment goals and ensure water safety and quality for reuse.

Biological Treatment:

- Activated Sludge Process:
 - microorganisms break down wastewater in an aerated tank.
- Sequencing Batch Reactor (SBR):
 - process treats wastewater in batches in a single tank.
- Trickling Filter:
 - spread over a media bed that contains a biofilm of microorganisms that degrade organic matter.

Chemical Treatment:

- **Coagulation and Flocculation:** coagulants to destabilize and aggregate suspended solids, allowing them to settle and be removed more easily.
- **Chemical Precipitation:** chemicals to wastewater to induce the formation of insoluble particles (precipitates) that can be separated from the water.
- **Disinfection:** The use of chemicals (e.g., chlorine, ozone, ultraviolet light) to destroy or inactivate pathogens in the wastewater.

Advanced Treatment:

- Membrane Filtration: fine pores separate suspended solids, bacteria, and other contaminants from wastewater.
- Advanced Oxidation Processes (AOPs): Employing chemical reactions (such as ozonation or UV/hydrogen peroxide) to break down persistent organic compounds and eliminate microorganisms.
- Adsorption: activated carbon or other materials to adsorb and remove organic compounds and contaminants from wastewater.

1. Wastewater Reuse Specific Technologies:

1. Reverse Osmosis (RO): A high-pressure membrane filtration
2. UV Disinfection: ultraviolet (UV) light to disinfect and inactivate pathogens, making it safe for specific reuse purposes.
3. Advanced Electrochemical Processes: use electrical current to treat wastewater and remove contaminants.

Recycling and Reuse: Not a Prescriptive Formula

1ST DRAFT (graphics to be added & slides will be shortened)

for

Onsite Wastewater Recycling Professionals

Presenter: Robert Sweeney, MS,
OR REHS / WA Professional Onsite Wastewater Treatment System Designer

___ October 2023

**This Presentation Represents the Opinion of the Author and Does
Not Reflect the Opinion of NOWRA, its Members or Sponsors of
the 2023 Mega-Conference.**



Bob Sweeney, MS, REHS
President, EMS,

- bob@envmgtsys.com O: 503-353-9691