



INFILTRATOR

water technologies



High Strength Waste How we do it in Texas

Dennis F. Hallahan, P.E., Technical Director

My Background:

- Professional Engineer
- Over 30 years in the decentralized wastewater industry
- Actively involved in Design, Serve on many boards, authored papers, research

This presentation is:

- High Strength Waste Best Practices
- Design recommendations and sources

Questions

1. **What is the expected design life of a typical residential system in your County?**
 - a. **0-5 years**
 - b. **5-10 years**
 - c. **10-20 years**
 - d. **Greater than 20 years *****

Questions

2. What is the expected design life of a typical restaurant system in your region?

- a. 0-5 years**
- b. 5-10 years *****
- c. 10-20 years**
- d. Greater than 20 years**

Questions

3. For High Strength Waste systems, I design based upon:

- a. Strictly Per code**
- b. Per code with extra considerations**
- c. Custom design per facility type**

Texas Specific HSW Rules

Flow Separation:

< 5,000 gpd Chapter 285

> 5,000 gpd Chapter 217

TCEQ Chapter 285

§285.32. Criteria for Sewage Treatment Systems

(f) Other Design Considerations.

(1) Restaurant/food establishment sewage. When designing for restaurants, food service establishments, or similar activities, the minimum design strength value shall be 1,200 mg/l Biochemical Oxygen Demand (BOD) after a properly sized grease trap/interceptor. It is the responsibility of the designer to properly design a system which reduces the wastewater strength to 140 mg/l BOD prior to disposal unless secondary treatment levels are required.

(2) Other high-strength sewage. For situations where sewage as defined in this chapter is expected to be a higher strength than residential sewage, it is the responsibility of the professional designer to justify sewage design strength estimations and properly design a system that reduces the wastewater strength to 140 mg/l BOD prior to disposal unless secondary treatment levels are required. Residential sewage is sewage that has a strength of less than 300 mg/l BOD.

What is high strength waste?

TX Code Definition – None

“Residential sewage is sewage that has a strength of less than 300 mg/l BOD.”

What about other constituents?

- **N, P, pH, FOG**
- **HSW = “Abnormal Waste” (industrial, chemical)**

Best Definition: HSW is anything other than Residential Waste



KNOW YOUR FACILITY TYPE

**Gathering information on influent
and effluent requirements**

Facility Types

RV Parks - Campgrounds

Schools

Rest Areas

Convenience Stores

Breweries

Wineries

**Hospitals – Health Care
Facilities**

Mobile Home Parks

Shopping Centers

Laundry Mats

Churches

BOD Strength & Restaurant Practices

BOD: 1200 mg/L (as dictated by code)
Some types of food produced higher
BOD

A menu review

- Sauces, sweets, etc.
- Alcohol service
- Grease, practices

Know facility practices

- Single service versus full plate service, or paper
- Ice generation
- Thawing Practices

Sampling of actual facilities

- Take more than one sample just after busy periods

Influent Characteristics & Flow

Resources for determining waste strength:

- 1. Literature**
- 2. Codes (LA)**
- 3. Similar Facilities**

Data: Flow data and sampling for strength, inspect the facility for usage habits

Literature: Restaurant BOD Strength

A study performed by Lesikar in 2004 in Texas demonstrated:

- 75% of wastewater samples from 28 different kinds of restaurants were 1400 mg/L or less with an average of 1000 mg/L.

Type of Restaurants	Number of Systems in Group	Average BOD mg/L
Fast Food/Burgers	6	974
Pizza	1	1856
Chinese	4	1364
Mexican	9	1254
American	1	1063
American Buffet	1	792
Steakhouse	2	601
Seafood	3	555

Louisiana Administrative Code

Title 51, Part XIII

Chapter 15. Sewage Loading Criteria [formerly Chapter 13 Appendix B]

§1501. General Requirements

A. See Note (a)

Place	Loading	Daily Average Flow Gallons per Day	Daily Average BOD ₅ Pounds per Day	Design Basis
Apartments		250	0.425	one bedroom
		300	0.52	two bedroom
		400	0.68	three bedroom
Assembly	Note (b)	2	0.0034	per seat
Bowling Alleys (no food service)	Note (b)	75	0.13	per lane
Churches	Note (b)	5	0.0088	per sanctuary seat
Churches (with permitted kitchens)	Note (c)	10	0.017	per sanctuary seat
Country Clubs		50	0.085	per member
Dance Halls	Note (b)	2	0.0034	per person
Drive-In Theaters		5	0.0085	per car space
Factories (no showers)		20	0.051	per employee
Factories (with showers)		35	0.06	per employee

Place	Loading	Daily Average Flow Gallons per Day	Daily Average BOD ₅ Pounds per Day	Design Basis
Food Service Operations				
Ordinary Restaurant (not 24 hour)		35	0.12	per seat
24-hour Restaurant		50	0.17	per seat
Banquet Rooms		5	0.017	per seat
Restaurant Along Freeway		100	0.33	per seat
Curb Service (drive-in)		50	0.17	per car space
Bar, Cocktail Lounges, Taverns (no food service or very little food service)		25	0.084	per seat
(with regular food service)		35	0.12	per seat
Video Poker Machine		100	0.20	per machine
Fast Food Restaurants		40	0.13	per seat

Place	Loading	Daily Average Flow Gallons per Day	Daily Average BOD ₅ Pounds per Day	Design Basis
Hotel/Motel Food Service		45	0.17	per room
Homes/ Mobile Homes in Subdivisions		400	0.68	per dwelling
Individual Homes/Mobile		250	0.425	one bedroom

PUBLIC HEALTH• SANITARY CODE

Hospitals (no resident personnel)	Note (c)	200	0.51	per bed
Institutions (residents)	Note (c)	100	0.25	per person
Municipalities		100	0.17	per person

Place	Loading	Daily Average Flow Gallons per Day	Daily Average BOD ₅ Pounds per Day	Design Basis
Mobile Home Parks				
up to 5 trailer spaces		400	0.68	per mobile home space
6 trailer spaces or more		300	0.51	per mobile home space
Motels	Note (b)	100	0.12	per unit
Nursing and Rest Homes	Note (c)	100	0.25	per patient
		100	0.17	per resident employee
Office Buildings		20	0.051	per employee
Recreational Vehicle Dumping Stations				Consult OPH
Recreational Vehicle Parks and Camps		125	0.21	per trailer or tent space
Retail Store		20	0.034	per employee
Schools• Elementary	Note (c)	15	0.038	per pupil
Schools• High and Junior High	Note (c)	20	0.051	per pupil

Place	Loading	Daily Average Flow Gallons per Day	Daily Average BOD ₅ Pounds per Day	Design Basis
Retail Fuel Stations (Located on major highways, etc., and whose primary function is to provide fuel and service to motor vehicles)	Note (d)	250	0.43	per individual vehicle fueling point (up to the first four)
		125	0.21	for each additional individual vehicle fueling point
Shopping Centers (no food service or laundries)		0.2	0.00034	per square foot of floor space
Swimming Pool (including employees)		10	0.017	per swimmer
Showers		20	0.04	per shower

Place	Loading	Daily Average Flow Gallons per Day	Daily Average BOD ₅ Pounds per Day	Design Basis
Vacation Cottages		50	0.12	per person
Youth and Recreation Camps	Note (c)	50	0.12	per person
Washing Machines		400	1.34	per machine

Louisiana Administrative Code

Title 51, Part XIII, Chapter 15

Place	Loading	Daily Average Flow Gallons per Day	Daily Average BOD ₅ Pounds per Day	Design Basis
Food Service Operations				
Ordinary Restaurant (not 24 hour)		35	0.12	per seat
24-hour Restaurant		50	0.17	per seat
Banquet Rooms		5	0.017	per seat
Restaurant Along Freeway		100	0.33	per seat
Curb Service (drive-in)		50	0.17	per car space
Bar, Cocktail Lounges, Taverns (no food service or very little food service)		25	0.084	per seat

Possible Design Considerations:

Increase Primary Tank Capacity

Increase Grease Trap Capacity

- “Tanks are cheap insurance”
- Increase frequency of pumping

Increase Drainfield Sizing

Alternate/resting of drainfields

Flow Equalization, pressure dosing/time dosing

Pretreatment

Outlet filters



HSW

Outlet Filters




USEPA 2002 Soil Loading Rates:

Table 4-3. Suggested hydraulic and organic loading rates for sizing infiltration surfaces

Texture	Structure		Hydraulic loading (gal/ft ² -day)		Organic loading (lb BOD/1000ft ² -day)	
	Shape	Grade	BOD=150	BOD=30	BOD=150	BOD=30
Coarse sand, sand, loamy coarse sand, loamy sand	Single grain	Structureless	0.8	1.6	1.00	0.40
Fine sand, very fine sand, loamy fine sand, loamy very fine sand	Single grain	Structureless	0.4	1.0	0.50	0.25
Coarse sandy loam, sandy loam	Massive	Structureless	0.2	0.6	0.25	0.15
	Platy	Weak	0.2	0.5	0.25	0.13
		Moderate, strong				
	Prismatic, blocky, granular	Weak	0.4	0.7	0.50	0.18
		Moderate, strong	0.6	1.0	0.75	0.25
Fine sandy loam, very fine sandy loam	Massive	Structureless	0.2	0.5	0.25	0.13
	Platy	Weak, mod., strong				
	Prismatic, blocky, granular	Weak	0.2	0.6	0.25	0.15
		Moderate, strong	0.4	0.8	0.50	0.20

Increasing Drainfield Size

- Increased System Size: Spread out the load over more area
- Land Intensive: Large footprint
- Multiple fields are a good option
- Seasonal facilities offer a factor of safety
- In General: high BOD and/or high FOG the soil is not a good medium for treatment



Comparing hydraulic and organic mass loadings for a restaurant wastewater

Given Info:

Design Flow: 600 gpd

BOD: 1200 mg/l

Soil: loam, 0.6 gpd/sf
loading rate

Hydraulic Loading:

Required Area =

$$(600 \text{ gpd}) / (0.6 \text{ gpd/sf}) =$$

1,000 sf

Organic loading: STE: BOD = 140 mg/l

$$\begin{aligned} \text{Organic Loading} &= (140 \text{ mg/l})(0.6 \text{ gpd/sf})(8.34) \\ &= 7.5 \times 10^4 \text{ lb BOD/sf/d} \end{aligned}$$

Therefore 0.00075 lb BOD/ft²/d is the soils' design organic loading rate

Now compensating for the increased waste strength:

$$\text{Area} = \frac{(1200 \text{ mg/l})(600 \text{ gpd})(8.34)}{(7.5 \times 10^{-4} \text{ lb BOD/sf/d})}$$

$$= \frac{(4.0 \text{ lb BOD})}{(7.5 \times 10^{-4} \text{ lb BOD/sf/d})}$$

$$= \mathbf{5337 \text{ sf}} \text{ (540\% increase)}$$

Restaurant Flows:

92K gpd/month (+/-)

23K gpd/week

3,300 gpd on avg

Sat&Sun **6,000 gpd**


The Flow Trap

Design based upon flow only

Metering data

- Monthly average

Actual Flow \neq Design Flow



Peak Flow Event Facility



Retention Time: Residential vs Commercial

Residential System:

3 bedroom home, 3 persons (US Census 2.8), 1000 gal tank, actual water usage 50 gpd/person.

Retention time:

$$(1000 \text{ gal}) / (150 \text{ gpd}) = \underline{6.7 \text{ days}}$$

Retention Time: Residential vs Commercial

Commercial System

Tank Sizing per Code: 24 or 48 hours

Retention time: 1 to 2 Days

Table II. Septic Tank Minimum Liquid Capacity.

SEPTIC TANK MINIMUM LIQUID CAPACITY

A. Determine the applicable wastewater usage rate (Q) in TABLE III of 30 TAC Chapter 285.

B. Calculate the minimum septic tank volume (V) as follows:

1. For Q equal to or less than 250 gal/day:

$$V = 750 \text{ gallons}$$

2. For Q greater than or equal to 251 gal/day but less than or equal to 350 gal/day:

$$V = 1000 \text{ gallons}$$

3. For Q greater than or equal to 351 gal/day but less than or equal to 500 gal/day:

$$V = 1250 \text{ gallons}$$

4. For Q greater than or equal to 501 gal/day but less than or equal to 1000 gal/day:

$$V = 2.5 Q$$

5. For Q greater than or equal to 1001 gal/day:

$$V = 1,750 + 0.75Q$$

Per 285:

Say: 5,000 gpd (4,999...)

$$V = 1,750 + 0.75Q$$

$$V = 1,750 = 0.75(5,000) = 5,500 \text{ gallons}$$

Retention time:

$$(5,500 \text{ gal}) / (5,000 \text{ gpd}) = \underline{1.1 \text{ days}}$$

$$(5,500 \text{ gal}) / (3,333 \text{ gpd}) = \underline{1.65 \text{ days}}$$

Operations and Maintenance



STRESS THE IMPORTANCE
OF O&M TO THE OWNER



DESIGN WITH O&M IN MIND
ACCESS, SAMPLING, SAFETY

HSW State Code Noteables:

- **MN & WI – Product Review and Registration, Mass loading, Mfg must sign off and O&M required (WI requires 30-30)**
- **TX, GA and CO**
- **NC & WA – Design based upon mass loading**
- **VT, ME**

**Division of Environmental Health
Maine Center for Disease Control & Prevention
Department of Health and Human Services
STATE OF MAINE**

SUBSURFACE WASTEWATER DISPOSAL RULES

H. ADJUSTMENTS FOR EFFLUENT QUALITY

1. Facilities other than residential, using water records to determine design flows, must also comply with Sections 4(G) and 4(H). (The Minimum Lot Size Law may also apply).
2. Factor: Adjustment for restaurant and commercial/institutional food preparation waste: Disposal areas for restaurants must be increased by 80 percent (multiplied by 1.8) to accommodate the additional organic loading typical of such facilities. This multiplying factor may be decreased by using the following criteria:


TABLE 4B
ADJUSTMENT FACTOR FOR WASTEWATER STRENGTHS
DIFFERENT FROM TYPICAL DOMESTIC WASTEWATER

Strength of wastewater entering the disposal field (BOD5 plus TSS)	Adjustment factor (AF)
30 or less milligrams/liter	0.5
52	0.6
82	0.7
122	0.8
175	0.9
240	1.0
320	1.1
420	1.2
530	1.3
660	1.4
810	1.5
985	1.6
1180	1.7
1400	1.8
1645	1.9
2000	2.0

Treating High Strength Waste


Advanced Treatment

ECOPOD



3rd
Party Pilot
Testing

Package Treatment Plants




10 States
Standard
(GLUMRB)

Advanced Treatment for HSW

Decentralized Applications


- Submerged Fixed Film Attached Growth Process
- 2,000 – 100,000 GPD
- Low Cost
- Commercial/Community
- Minimal Maintenance



Extended Aeration Package Plant

Decentralized Applications

- 500 – 250,000 GPD
- Activated Sludge Process
- Low Cost
- Commercial/Multi Community
- Moderate Maintenance



Texas Specific HSW Rules

Chapter 217



Case Study: RV Park WWTP – Waller, TX

- **30,000 gpd Average Daily Flow**
- **Two Parallel 15K gpd Aeration Basins in Single Tank Construction**
- **10' Diameter Mechanical Secondary Clarifier**
- **Effluent Pump Tank with Duplex Pumps and Controls for Spray Dispersal**
- **304 Stainless Steel Air Drops**
- **Galvanized Steel Stairs, Walkways, Handrails**
- **Interior surface prepped to near white (SP10); Coating is Tnemec Series 69 epoxy**



Case Study: Pilot Gas Station – Pyote, Texas

Design Flow: 5,000 gpd

Influent Waste Strength: 1500 mg/L BOD, 200 mg/L TSS

Treatment Limits: 140 mg/l BOD or less (50 mg/l design)


Tankage: 15,000 gal Primary Tank, 2 Compartment, Trash/Flow EQ Tank with Effluent Filters

4 – 6,000 Gallon Concrete Tanks with (4) E2000D EcoPod

1 – 6,000 Gallon Pump Tank

Subsurface Discharge: 1,350 Q4+High Capacity Chambers

Schematic Plan







Drainfield



Case Study: O&G Man Camp – Midland, TX

Design Flow: 4,999 gpd
WW Strength: 350 mg/L BOD
E600D Ecopod
Treatment to 10/10 (spray)
Primary Tank – 5,000 gal
Flow EQ Tank
Aeration Chamber – 8,500 gal
Chlorination Tank
Pump Tank – 1,500 gal



Q:\Technical Resources New\02-151-PRODUCTS\95 - Delta Products\PACKAGE PLANTS - STP\MIDLAND ECOPOD-PLANT

PLAN




ATCH ACCESS



AERATION	CHLORINE TANK
VOLUME: 8,138 GALS.	VOLUME: 157 GALS.
DETENTION: 39.1 HRS	DETENTION: 45 MIN.
AVERAGE FLOW	AVERAGE FLOW
AIR DROPLINES: 4 TOTAL	
DIFFUSERS: 16 TOTAL	
SHIPPING WEIGHT: 20,000 LBS.	
OPERATING WEIGHT: 195,000 LBS.	

- NOTES:
 1) CHLORINATOR TYPE: CALCIUM HYDROCHLORIDE TABLET
 2) THREE (3) SIMPLEX REGENERATIVE BLOWERS AND CONTROLS
 3) BIOLOGICAL LOADING: 14.6 LBS./DAY, BOD AT 350 PPM.
 4) 3 BREAKERS (50-70-50 AMPS)

ELEVATION



10/16/15	MODIFIED BY: Edgar Alvis
REV	DATE
	REVISION DESCRIPTION
	BY




MIDLAND ECOPOD-PLANT
 4,999 GPD STP W/ PUMP TANK

COMPANY CONFIDENTIAL INFORMATION CONTAINED HEREIN IS CONFIDENTIAL AND IT IS THE PROPERTY OF DELTA TREATMENT SYSTEMS. IT IS TO BE USED SOLELY FOR THE PURPOSE PROVIDED, AND IT IS NOT TO BE DISCLOSED TO OTHERS WITHOUT THE PRIOR WRITTEN CONSENT OF DELTA TREATMENT SYSTEMS.

PLDT SCALE NTS	DRAWING NUMBER	DRAWN BY EDGAR ALVIS	DATE 11/07/19	SHEET 1 OF 1	REV 1
-------------------	----------------	-------------------------	------------------	-----------------	----------











Conclusions:

- 1. HSW is complicated, no one-size-fits-all**
- 2. Waste strength is the most critical design item.**
- 3. O&M, O&M, O&M – design for it, stress the importance to the owner**

Thanks - Questions

**Infiltrator High Strength Waste
Design recommendations/Best
Practices white paper is
available**

Dennis F. Hallahan, P.E.

Technical Director

dhallahan@infiltratorwater.com