

**high-strength wastewater**

1. Influent having BOD5 greater than 300 mg/L; and/or TSS greater than 200 mg/L; and/or fats, oils, and grease greater than 50 mg/L entering a treatment component (as defined by NSF Standard 40 testing protocol); 2. Effluent exiting a septic tank or other pretreatment component that has BOD5 greater than 170 mg/L; and/or TSS greater than 60 mg/L; and/or fats, oils, and grease greater than 25 mg/L and is applied to an infiltrative surface.